



# Low-Emitting Materials

## MAS Certified Green® Certificate of Compliance

Awarded to:

**INTERNATIONAL MARBLE INDUSTRIES, INC. OF  
WOODSTOCK, GA** **304 BELL PARK DRIVE; ZIP CODE: 30188**

Category:

Construction Materials - Cultured Marble Panels

Cert. Scheme:

VOC Emissions

Accredited  
Compliance  
Designation:

California Dept. of Public Health Standard Method v1.2 single family residence

\*Conforms  
With:

LEED v4.1 ID+C, BD+C

low-emitting interiors

Criteria of MAS Certified Green® Program

low-emitting material

TVOC Emissions at 14-days

0.5 mg/m<sup>3</sup> or less

Bracketed  
Products:

Shower Bases: General, 34", 36", 40", 42", 48", 54", 58", 60", 62", 64", 66", 72".

Shower & Tub Surrounds: Traditional, Vertical Text, Textured, Tile.

Accessories: Accessory Ledges, Non-Slip Foot Rest, 7x7 Angular Foot Rest,  
7x7 Shampoo Shelf, 3-Piece Corner Mount Shampoo Shelf, 3-Piece Corner Mount  
Foot Rest, Flat Trims, Window Sill

Test Date  
& Report No.:

July 3, 2019

1900861

Certificate No.: MAS1900861

valid July 2019 to July 2020



Product Certifier, MAS Certified Green

Testing Cert. # 2925.01  
Product Cert. # 2925.02

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025

3<sup>rd</sup> Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065

\*outside of A2LA accreditation scope